

Permit # _____ Town or Village Fee _____

Date _____

Town of Aurora**575 Oakwood Avenue, East Aurora, New York 14052****PERMIT APPLICATION****NY State Unified Solar Permit**

Unified solar permitting is available statewide for eligible solar photovoltaic (PV) installations. Municipal authorities that adopt the unified permit streamline their process while providing consistent and thorough review of solar PV permitting applications and installations. Upon approval of this application and supporting documentation, the authority having jurisdiction (AHJ) will issue a building permit for the solar PV installation described herein.

PROJECT ELIGIBILITY FOR UNIFIED PERMITTING PROCESS

By submitting this application, the applicant attests that the proposed project meets the established eligibility criteria for the unified permitting process (subject to verification by the AHJ). The proposed solar PV system installation:

- | | | |
|------------------------------|-----------------------------|---|
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 1. Has a rated DC capacity of 25 kW or less. |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 2. Is not subject to review by an Architectural or Historical Review Board. (If review has already been issued answer YES and attach a copy) |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 3. Does not need a zoning variance or special use permit. (If variance or permit has already been issued answer YES and attach a copy) |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 4. Is mounted on a permitted roof structure, on a legal accessory structure, or ground mounted on the applicant's property. If on a legal accessory structure, a diagram showing existing electrical connection to structure is attached. |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 5. The Solar Installation Contractor complies with all licensing and other requirements of the jurisdiction and the State. |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 6. If the structure is a sloped roof, solar panels are mounted parallel to the roof surface. |

For solar PV systems not meeting these eligibility criteria, the applicant is not eligible for the Unified Solar Permit and must submit conventional permit applications. Permit applications may be downloaded here: www.townofaurora.com or obtained in person at the Town of Aurora Building Department, 575 Oakwood Ave, East Aurora NY during business hours of 8:30am-4:30pm Monday-Friday.

SUBMITTAL INSTRUCTIONS

For projects meeting the eligibility criteria, this application and the following attachments will constitute the Unified Solar Permitting package.

- This application form, with all fields completed and bearing relevant signatures.
- Permitting fee of \$50.00, payable by cash or check payable to "Town of Aurora."
- Building permit fee of \$0.10 per square foot of solar panel.
- Required Construction Documents for the solar PV system type being installed, including required attachments.
- Property survey showing location of system and distances of system from front, rear, and side lot lines.

Completed permit applications can be submitted to the Town of Aurora Building Department, 575 Oakwood Avenue, East Aurora, NY from 8:30am-4:30pm Monday-Friday.

APPLICATION REVIEW TIMELINE

Permit determinations will be issued within thirty (30) calendar days upon receipt of complete and accurate applications. The municipality will provide feedback within fifteen (15) calendar days of receiving incomplete or inaccurate applications.

FOR FURTHER INFORMATION

Questions about this permitting process may be directed to the Town of Aurora Building Department at 716-652-7591 or building@townofaurora.com.

Permit # _____ Town or Village Fee _____ Date _____

PROPERTY OWNER

Property Owner's First Name _____ Last Name _____ Title _____

Property Address _____

City _____ State _____ Zip _____

SBL _____ Zoning District _____

EXISTING USE

- Single Family
- 2-4 Family
- Commercial
- Other

PROVIDE THE TOTAL SYSTEM CAPACITY RATING (SUM OF ALL PANELS)

Solar PV System: _____ kW DC

SELECT SYSTEM CONFIGURATION

Make sure your selection matches the Construction Documents included with this application.

- Supply side connection with microinverters
- Supply side connection with DC optimizers
- Supply side connection with string inverter
- Load side connection with DC optimizers
- Load side connection with microinverters
- Load side connection with string inverter

SOLAR INSTALLATION CONTRACTOR

Contractor Business Name _____

Contractor Business Address _____ City _____ State _____ Zip _____

Contractor Contact Name _____ Phone Number _____

Contractor License Number(s) _____ Contractor Email _____

Electrician Business Name _____

Electrician Business Address _____ City _____ State _____ Zip _____

Electrician Contact Name _____ Phone Number _____

Electrician License Number(s) _____ Electrician Email _____

Please sign below to affirm that all answers are correct and that you have met all the conditions and requirements to submit a unified solar permit.

Property Owner's Signature _____ Date _____

Solar Installation Company Representative Signature _____ Date _____

Permit # _____ Town or Village Fee _____

Date _____

SUBMITTAL REQUIREMENTS SOLAR PV 25KW OR LESS (ATTACHMENTS)**NY State Unified Solar Permit**

This information bulleting is published to guide applicants through the unified solar PV permitting process for solar photovoltaic (PV) projects 25KW in size or smaller. This bulletin provides information about submittal requirements for required fees and inspections.

PERMITS AND APPROVALS REQUIRED

The following permits are required to install a solar PV system with a nameplate DC power outlet of 25kW or less:

- a) Unified Solar Permit
- b) Electrical Inspection by 3rd party Electrical Inspector approved by Town of Aurora and the list is available in the Town of Aurora Building Department.

SUBMITTAL REQUIREMENTS

In order to submit a complete permit application for a new solar PV system, the applicant must include:

- a) Completed Unified Solar Permit Application form which includes confirmed eligibility for the Unified Solar Permitting process. This permit application form can be downloaded at www.townofaurora.com.
- b) Construction Documents, with listed attachments (see below). Construction Documents must be by stamped and signed by a New York State Registered Architect or New York State Licensed Professional Engineer.

The Town of Aurora, through adopting the Unified Solar Permitting process, requires contractors to provide construction documents, such as the examples included in the Understanding Solar PV Permitting and Inspecting in New York State document. Should the applicant wish to submit Construction Documents in another format, ensure that the submittal includes the following information:

- Manufacturer/model number/quantity of solar PV modules and inverter(s).
 - String configuration for solar PV array, clearly indicating the number of modules in series and strings in parallel (if applicable).
 - Combiner boxes: Manufacturer, model number, NEMA rating.
 - From array to the point of interconnection with existing (or new) electrical distribution equipment: identification of all raceways (conduit, boxes, fittings, etc.), conductors and cable assemblies, including size and type of raceways, conductors, and cable assemblies.
 - Sizing and location of the EGC (equipment grounding conductor).
 - Sizing and location of GEC (grounding electrode conductor, if applicable).
 - Disconnecting means of both AC and DC including indication of voltage, ampere, and NEMA rating.
 - Interconnection type/location (supply side or load side connection)
 - For supply side connections only, indication that breaker or disconnect meets or exceeds available utility fault current rating kAIC (amps interrupting capacity in thousands).
 - Ratings of service entrance conductors (size insulation type AL or CU), proposed service disconnect, and overcurrent protection device for new supply side connected solar PV system (reference NEC 230.82, 230.70).
 - Rapid shutdown device location/method and relevant labeling.
 - Property survey showing location of system with front, side, and rear setbacks marked for ground mounted systems.
- c) For Roof Mounted Systems - A roof plan showing roof layout, solar PV panels and the following fire safety items: approximate location of roof access point, location of code-compliant access pathways, code exemptions, solar PV system fire classification, and the locations of all required labels and marking.

Permit # _____ Town or Village Fee _____

Date _____

d) Provide construction drawings with the following information:

- The type of roof covering and the number of roof coverings installed.
- Type of roof framing, size of members, and spacing.
- Weight of panels, support locations, and method of attachment.
- Framing plan and details for any work necessary to strengthen the existing roof structure.
- Site-specific structural calculations.

e) Where an approved racking system is used, provide documentation showing manufacturer of the racking system, maximum allowable weight the system can support, attachment method to roof or ground, and product evaluation information or structural design for the rack.

f) For Roof and Building Mounted Systems - A letter from a Registered Architect or Professional Engineer indicating the structural integrity post installation.

PLAN REVIEW

Permit applications can be submitted to the Town of Aurora Building Department, 575 Oakwood Ave, East Aurora, New York from 8:30am-4:30pm Monday-Friday.

FEES

- Application Fee \$50.00
- Building Permit Fee \$0.10 per square foot of solar panel

INSPECTIONS

Once all permits to construct the solar PV installation have been issued and the system has been installed, it must be inspected before final approval is granted for the solar PV system. On-site inspections can be scheduled by contacting the Town of Aurora Building Department at 716-652-7591. Inspections requests received within business hours are typically scheduled the next business day. The Town of Aurora utilizes approved 3rd party Electrical Inspection Agencies for all electrical inspections. The approved list is available at www.townofaurora.com.

In order to receive final approval, the following inspections are required:

FOUNDATION INSPECTION: For systems requiring a footing/foundation, an inspection is required prior to pouring concrete.

ROUGH INSPECTION: During a rough inspection, the applicant must demonstrate that the work in progress complies with relevant codes and standards. The purpose of the rough inspection is to allow the inspector to view aspects of the system that may be concealed once the system is complete, such as:

- Wiring concealed by new construction - through the Town of Aurora approved 3rd party Electrical Inspection Agency.
- Portions of the system that are contained in trenches or foundations that will be buried upon completion of the system – through the Town of Aurora Building Department.

It is the responsibility of the applicant to notify the Town of Aurora Building Department and the approved Electrical Inspection Agency before the components are buried or concealed and to provide safe access (including necessary climbing and fall arrest equipment) to the inspector. The inspector will attempt, if possible, to accommodate requests for rough inspections in a timely manner.

FINAL INSPECTION: The applicant must contact the Town of Aurora Building Department when ready for a final inspection. During this inspection, the inspector will review the complete installation to ensure compliance with codes and standards, as well as confirming that the installation matches the records included with the permit application. The applicant must have ready, at the time of inspection, the following materials and make them available to the inspector:

- Copies of as-built drawings and equipment specifications, if different than the materials provided with the application.
- Photographs of key hard to access equipment, including;
 - Example of array attachment point and flashing/sealing methods used.
 - Opened rooftop enclosures, combiners, and junction boxes.
 - Bonding point with premises grounding electrode system.
 - Supply side connection tap method/device.

Permit # _____ Town or Village _____ Fee _____ Date _____

- Module and microinverter/DC optimizer nameplates.
- Microinverter/DC optimizer attachment.

The Town of Aurora has adopted a standardized inspection checklist, which can be found in the Understanding Solar PV Permitting and Inspecting in New York State document, found here: www.townofaurora.com

The inspection checklist provides an overview of common points of inspection that the applicant should be prepared to show compliance. If not available, common checks include the following:

- Number of solar PV modules and model number match plans and specification sheets number match plans and specification sheets.
- Array conductors and components are installed in a neat and workman-like manner.
- Solar PV array is properly grounded.
- Electrical boxes and connections are suitable for environment.
- Array is fastened and sealed according to attachment detail.
- Conductor’s ratings and sizes match plans.
- Appropriate signs are property constructed, installed and displayed, including the following:
 - Sign identifying PV power source system attributes at DC disconnect.
 - Sign identifying AC point of connection.
 - Rapid shutdown device meets applicable requirements of NEC 690.12.
- Equipment ratings are consistent with application and installed signs on the installation, including the following:
 - Inverter has a rating as high as max voltage on PV power source sign.
 - DC-side overcurrent circuit protection devices (OCPDs) are DC rated at least as high as max voltage on sign.
 - Inverter is rated for the site AC voltage supplied and shown on the AC point of connection sign.
 - OCPD connected to the AC output of the inverter is rated at least 125% of maximum current on sign and is no larger than the maximum OCPD on the inverter listing label.
 - Sum of the main OCPD and the inverter OCPD is rated for not more than 120% of the buss bar rating.

UNIFIED SOLAR PERMITTING RESOURCES

The jurisdiction has adopted the following documents from the New York Unified Solar Permit process which can be found on the Town of Aurora website at www.townofaurora.com:

- Unified Solar Permit application
- Understanding Solar PV Permitting and Inspecting in New York State document, which includes sample construction documents, inspection checklist, design review checklist, and labelling guide

DEPARTMENTAL CONTACT INFORMATION

For additional information regarding this permit process, please consult the Town of Aurora Building Department at 716-652-7591.

TOWN OF AURORA PERMIT APPROVAL

Signature of Code Enforcement Officer/Building Inspector

Receipt is hereby acknowledged the sum of \$ _____ equal to the fees established by the Town Board of the Town of Aurora NY

Town Clerk/Deputy Clerk

